




9 Aston Street
BLENHEIM
Telephone 021-343 089
After hours 0-3-578 8270
Facsimile 0-3-578 8166



U700420 - bore
Water Take - 0970733
P. 162376



WATER WELL ENGINEERS TO MARLBOROUGH

WELLD RILLING LOG

P28w/3304

WELL OWNER Mr M Bishell

ADDRESS Caythorp
Middle Renwick Road
Blenheim

DRILLING DATE Jan 98

MACHINE No 2 Rotary

LOCALITY Woodbourne

GRID REFERENCE 41.31.08s 173.52.41e

N.Z.G.S.WELL No P28w/3304.

PERMIT No

~~2583455 - 5965420~~
2583427 - 5965539

REDUCED LEVEL OF WELLSITE (m above mean sea level)

MATERIALS ENCOUNTERED

0-1.1 gravally top soil
1.1-5.1 yellow clays
5.1-6.4 yellow clays , brown pebbles
6.4-10.5 brown clean gravals
10.5-14.5 brown & blue gravals , claybound
14.5-17.5 brown gravals yellow clays pwb
17.5-22.1 brown gravals yellow clay mwb

STATIC WATER LEVEL 10.84

CASING DIAMETER 100mm LENGTH 18.4

SCREEN TYPE 80mm slotted pvc SET AT 18.4-21.35

SLOT SIZE 10mm DRAW DOWN 0.51

AFTER 3 HOURS PUMPING AT 102 LITRES / MIN

REMARKS

Well flanged above ground level ready for pump conection