



4 Springswood Grove
 BLENHEIM
 Telephone 021-343 089
 After hours 0-3-578 8270
 Facsimile 0-3-578 8166



U991082

WATER WELL ENGINEERS TO MARLBOROUGH

Log No 956

Well Owner Rarangi Holdings Trust
 C/o P.J.Woolley
 Hunters Road
 Tuamarina

Contact Name Philip Woolley

Driller Rob Millard

Map Sheet No

Altitude (m):

Drilling Date 16/05/2005

Grid Ref East:

South

Locality Stage 2 Lot 55 Grid ref 2596102-5974799

P282/3544

Depth To Strata Top (m)	Strata Bottom (m)	Strata Thickness (m)	Static Level (m)	Strata Description	Strata Picture
0.00	9.60	9.60		Grey fine gravel to coarse sand, and shellfish shells	
9.60	10.80	1.20		Grey marine sand	

Casing above ground (mm): 300

Finished Static
 Water Level: 4.03

Test Pumping: 2.00 Hours

Draw Down (m): 3.02 Below Static Water Level

Flow Rate: 2.33 cubic mph

Step Test By:

No: 1 Screen Type Ss wedge wire

Top of Screen Leader (m): 7.65

Top Of Screen (m): 7.65

From:	To:	Slot Size	Length
7.65	9.15	0.25	1.50

Bottom Of Screen (m) 9.15

Length of Sump (m): 0.30

Finished Depth of Well (m) 9.45

Casing NB Dia
(mm): 80

Screen NB Dia
(mm): 100

Ground Level

Leader Length
(m): 0.00

Casing Length
(m): 7.65

Total Screen
 Length (m): 1.50

Remarks:
 Casing is Pvc

PLEASE NOTE:

Test pumping flow rates, static levels, and water level draw down are as recorded at the time of test pumping. These figures could change at a later time due to influences beyond our control (e.g. seasonal variations).


30/05/2005 9:25:38 p.m.

Page 1 of 1

Wells P28w/3528 - P28w/3555

RECEIVED
- 4 AUG 2005
MARLBOROUGH
DISTRICT COUNCIL

LEGEND



Sewage disposal
fields

Coordinates in terms of
New Zealand Map Grid

