



4 Springswood Grove
 BLENHEIM
 Telephone 021-343 089
 After hours 0-3-578 8270
 Facsimile 0-3-578 8166

F24w/p182



WATER WELL ENGINEERS TO MARLBOROUGH

Log No 997

4050118.

Well Owner Toi Downs Ltd
 P.O.Box 164
 Blenheim

Contact Name Mr D McFarlane

Driller John Butt

Map Sheet No

Altitude (m):

Drilling Date 07/10/2005

Grid Ref East:

South

Locality Awatere River bed Grid ref 2604474-5953944

Depth To Strata Top (m)	Strata Bottom (m)	Strata Thickness (m)	Static Level (m)	Strata Description	Strata Picture
0.00	3.80	3.80		Brown and grey cobble to medium sand, yellow clay bound	
3.80	17.30	13.50		Grey clay (Papa)	

Finished Static Water Level: 5.05


Test Pumping: 3.00 Hours

Draw Down (m): 0.10 Below Static Water Level

Flow Rate: 43.52 cubic mph

Step Test By:

No: 1 Screen Type slotted Pvc



Remarks:

Well is an infiltration gallery
 Grid ref of trench end 260559-5953875



4 Springswood Grove
BLENHEIM
Telephone 021-343 089
After hours 0-3-578 8270
Facsimile 0-3-578 8166



WATER WELL ENGINEERS TO MARLBOROUGH

PLEASE NOTE:

Test pumping flow rates, static levels, and water level draw down are as recorded at the time of test pumping. These figures could change at a later time due to influences beyond our control (e.g. seasonal variations).