



4 Springswood Grove
 BLENHEIM
 Telephone 021-343 089
 After hours 0-3-578 8270
 Facsimile 0-3-578 8166



WATER WELL ENGINEERS TO MARLBOROUGH

Log No 1583

Well Owner Richardson Bros
 15 Neal Road
 RD3 Blenheim

Contact Name

U160943
 10763

Driller John Butt

Map Sheet No

Altitude (m):

Drilling Date 01/11/2016

Grid Ref East:

South

Locality Kiatuna Grid ref 1668080-5409135

Depth To Strata Top (m)	Strata Bottom (m)	Strata Thickness (m)	Static Level (m)	Strata Description	Strata Picture
0.00	0.30	0.30		Fill, miscellaneous	
0.30	13.50	13.20		Brown and grey cobble to medium sand, yellow clay bound	
13.50	16.90	3.40		Brown and grey cobble to medium sand, some yellow clay, water bearing	

**Finished Static
 Water Level:** 4.92

Test Pumping: 2.00 **Hours**

Draw Down (m): 0.15 **Below Static Water Level**

Flow Rate: 5.45 **cubic mph**

Step Test By:

No: 1 **Screen Type** Slotted 80mm Pvc

Remarks:

Casing above ground (mm): 400

**Casing NB Dia
 (mm):** 100

Ground Level

**Screen NB Dia
 (mm):** 80

**Leader Length
 (m):** 0.30

Top of Screen Leader (m): 14.14

Top Of Screen (m): 14.44

**Casing Length
 (m):** 14.44

From:	To:	Slot Size	Length
14.44	16.67	4.00	2.23

Bottom Of Screen (m): 16.67

Length of Sump (m): 0.00

**Total Screen
 Length (m):** 2.23

Finished Depth of Well (m): 16.67



4 Springswood Grove
BLENHEIM
Telephone 021-343 089
After hours 0-3-578 8270
Facsimile 0-3-578 8166



WATER WELL ENGINEERS TO MARLBOROUGH

PLEASE NOTE:

Test pumping flow rates, static levels, and water level draw down are as recorded at the time of test pumping. These figures could change at a later time due to influences beyond our control (e.g. seasonal variations).


Sue Bulfield-Johnston-5141

From: John Butt <john@buttdrilling.co.nz>
Sent: Wednesday, 21 June 2017 5:47 p.m.
To: Sue Bulfield-Johnston-5141
Subject: RE: Well log 1583 - Richardson Bros, Kaituna

Sue

Yes that well is on the coordinates on the log, it replaced on old shallow dug linner well.

Best regards John Butt



4 Springswood Grove
Blenheim

T: 021 343 089 | after hours: 03 578 8270

john@buttdrilling.co.nz | <http://www.buttdrilling.co.nz>

WATER WELL ENGINEERS TO MARLBOROUGH



From: Sue Bulfield-Johnston-5141 [<mailto:Sue.Bulfield-Johnston@marlborough.govt.nz>]
Sent: Wednesday, 21 June 2017 11:33 AM
To: John Butt <john@buttdrilling.co.nz>
Subject: Well log 1583 - Richardson Bros, Kaituna

Hi John

Can you please check the coordinates for the well log 1583 (your reference).
The coordinates place the well beside a tank and an existing well (P28w3428).

The well you have drilled may be associated with resource consent U160943 – to construct a new domestic bore on Lot 1 DP 8727, granted to Kaituna Park Limited.
Can you confirm this is the case?

Many thanks

Sue Bulfield-Johnston

Administration Officer/Hearings Facilitator
MARLBOROUGH DISTRICT COUNCIL
Phone: 03 520 7400

15 Seymour Street, PO Box 443
Blenheim 7240, New Zealand

Email: sue.bulfield-johnston@marlborough.govt.nz
Web: www.marlborough.govt.nz

This email, including any attachments, is confidential and may contain legally privileged material and is only for the use of the intended recipient. If you are not the intended recipient then any use, dissemination, distribution or copying of this message is strictly prohibited. If you have received this email in error please notify us immediately and delete the original message. This email does not necessarily represent the views of the Marlborough District Council. Thank you.

