



4 Springswood Grove
 BLENHEIM
 Telephone 021-343 089
 After hours 0-3-578 8270
 Facsimile 0-3-578 8166



170070

WATER WELL ENGINEERS TO MARLBOROUGH

Log No 1620

Well 10808

Well Owner Constellation Brands NZ Ltd
 P.O.Box 260
 Blenheim

Contact Name Ollie Davidson

Driller John Butt

Map Sheet No


Altitude (m):

Drilling Date 28/07/2017

Grid Ref East:

South

Locality Hamericks Road Grid ref 1675903-5406837

Depth To Strata Top (m)	Strata Bottom (m)	Strata Thickness (m)	Static Level (m)	Strata Description	Strata Picture
0.00	0.40	0.40		Brown coarse gravel and silt	

Finished Static Water Level: 2.27


Test Pumping: 0.00 Hours

Draw Down (m): 0.00 Below Static Water Level

Flow Rate: 0.00 cubic mph

Step Test By:

No: 1 Screen Type Slotted 50mm Pvc with filt



Remarks:

Well set up as a monitor bore.

PLEASE NOTE:

Test pumping flow rates, static levels, and water level draw down are as recorded at the time of test pumping. These figures could change at a later time due to influences beyond our control (e.g. seasonal variations).

Project Ref: 70256

14 August 2017

Marlborough District Council
 PO Box 443
 Blenheim 7201

Attention: Compliance Manager

Dear Sir/Madam,

CONSTELLATION BRANDS NZ LTD LAND USE U170070 COMPLIANCE FOR NEW BORES

Consent U170070 allowed for the installation of two ground water monitoring bores.

These were installed by Butt Drilling on 27 & 28 July 2017, with no contaminated soils encountered during the drilling process.

The GPS locations area set out in the table below with photos and the bore logs attached.

GPS Locations are:

Bore No	mE (NZTM)	mN (NZTM)	Height (above MSL)	Comment
10808	1675899	5406837	14.33	Located off Hammerichs Road
10809	1677673	5407230	10.49	Access off O'Dwyers Road



Photo 1: Bore no 10808



Photo 2: Bore no 10809

Yours faithfully



Vicki Nalder

Encl: Bore logs

cc: CBNZ
PO Box 260
Blenheim
Attn: Roy Seaton (by email)